



## F-GAS & BOTTLE LOG

CUSTOMER NAME ACL ENGINEERING LTD				SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION			SHEET NUMBER <span style="color: red; font-size: 1.2em;">00000</span>	
SITE NAME & ADDRESS (PLANT OWNER F-GAS) CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE				ENGINEER STEVE ORLANDO		CLIENT ASSET NUMBER 00000		
MANUFACTURER A MANUFACTURER		MODEL A MODEL NUMBER	SERIAL A SERIAL NUMBER	DATE INSTALLED 01/01/1980	PLANT REFERENCE A PLANT REFERENCE			
REFRIG TYPE R22	TOT. REFRIG CHR.G. 240.0 KG	INDIVIDUAL SYS. REF. CHARGE 60+60+60+60 KG		REFRIG GWP 1810	EQUIV. TONNES CO2e 434.4	F-GAS LEAK CHECK FREQ. HALF YEARLY	CLG LOAD SERVED A COOLING LOAD SERVED	

### VIRGIN REFRIGERANT BOTTLE LOG (KG)

DATE RECEIVED	DELIVERY NOTE NUMBER	BOTTLE NUMBER	SUPPLIER	REFRIGERANT	BOTTLE TYPE	GROSS WEIGHT	TARE WEIGHT	NET WEIGHT	NET USED	DATE RETURNED	RETURNS NOTE NUMBER

### RECOVERY BOTTLE LOG (KG)

DATE RECEIVED	DELIVERY NOTE NUMBER	BOTTLE NUMBER	SUPPLIER	REFRIGERANT	RECOVERY TYPE	TARE WEIGHT	RECOVERED NET	RECOVERED USED	GROSS WEIGHT	DATE RETURNED	WASTE TRANSFER NOTE

### F-GAS REFRIGERATION LOG RECORD

**REFRIGERANT ADDITIONS**

DATE	ENGINEER	AMOUNT ADDED (KG)	REASON FOR ADDITION

**REFRIGERANT REMOVALS**

DATE	ENGINEER	AMOUNT REMOVED (KG)	REASON FOR REMOVAL

**REFRIGERANT LEAK TEST**

DATE	ENGINEER	TEST RESULT	FOLLOW UP ACTIONS REQUIRED
00/01/1900	STEVE ORLANDO	PASS	PPM -

**FOLLOW UP ACTIONS**

DATE	ENGINEER	RELATED TO TEST ON	ACTIONS TAKEN

**TESTING AUTOMATIC LEAK DETECTION SYSTEM (IF FITTED)**

DATE	ENGINEER	TEST RESULT	COMMENTS

## SYSTEM TEST CERTIFICATES

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION			SHEET NUMBER <b>00000</b>
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO	F-GAS QUALIFICATION C&G 2079 PART 1		CLIENT ASSET NUMBER <b>00000</b>
REASON FOR VISIT A VISIT	MANUFACTURER A MANUFACTURER	MODEL A MODEL NUMBER			
JOB NUMBER A JOB	SERIAL No. A SERIAL NUMBER	YEAR INSTALLED 01/01/1980			
PLANT LOCATION A LOCATION	REFRIGERANT TYPE R22	QUANTITY (KG) 240.0 KG			
PLANT REFERENCE A PLANT REFERENCE	CLG LOAD SERVED A COOLING LOAD SERVED				

## STRENGTH TEST CERTIFICATE

### START OF STRENGTH TEST

DATE \_\_\_\_\_ TIME \_\_\_\_\_ PRESSURE \_\_\_\_\_ MOP \_\_\_\_\_

THE ABOVE SYSTEM / COMPONENT HAD A WITNESSED OFN NITROGEN STRENGTH TEST APPLIED AT 1.5 TIMES MOP (MAXIMUM OPERATING PRESSURE), MAINTAINED FOR 30 SECONDS.

INSTRUMENT USED: ITE HIGH SIDE GAUGE. CALABRATED: 25/11/2014.

INSTRUMENT SERIAL: FTEK-147. CERTIFICATE No. CM248650. NEXT DUE 25/11/2015.

ENGINEERS SIGNATURE \_\_\_\_\_ CUSTOMERS SIGNATURE \_\_\_\_\_  
F-GAS QUALIFICATION \_\_\_\_\_ C&G 2079 PART 1 \_\_\_\_\_ PRINT NAME \_\_\_\_\_ A NAME \_\_\_\_\_  
SIGNATURE DATE \_\_\_\_\_ 00/01/1900 \_\_\_\_\_ CUSTOMERS JOB TITLE \_\_\_\_\_ A POSITION \_\_\_\_\_

## PRESSURE TEST CERTIFICATE

### START OF PRESSURE TEST

DATE \_\_\_\_\_ TIME \_\_\_\_\_ PRESSURE \_\_\_\_\_ AMBIENT \_\_\_\_\_

### END OF PRESSURE TEST

DATE \_\_\_\_\_ TIME \_\_\_\_\_ PRESSURE \_\_\_\_\_ AMBIENT \_\_\_\_\_

### TEMPERATURE COMPENSATED NITROGEN PRESSURE FIGURE

CALCULATED CORRECTED END PRESSURE USING START PRESSURE AND START AMBIENT TEMPERATURE RELATIVE WITH FINISH AMBIENT TEMP. \_\_\_\_\_

THE ABOVE SYSTEM HAD A WITNESSED OFN NITROGEN PRESSURE TEST APPLIED, WHICH WAS MAINTAINED FOR THE PERIOD STATED ABOVE AND HAS BEEN PROVED TO REMAIN LEAK TIGHT

INSTRUMENT USED: CPS PROSET HIGH SIDE GAUGE. CALABRATED: 25/11/2014.

INSTRUMENT SERIAL: FTEK-045. CERTIFICATE No. CM248649. NEXT DUE 25/11/2015.

ENGINEERS SIGNATURE \_\_\_\_\_ CUSTOMERS SIGNATURE \_\_\_\_\_  
F-GAS QUALIFICATION \_\_\_\_\_ C&G 2079 PART 1 \_\_\_\_\_ PRINT NAME \_\_\_\_\_ A NAME \_\_\_\_\_  
SIGNATURE DATE \_\_\_\_\_ 00/01/1900 \_\_\_\_\_ CUSTOMERS JOB TITLE \_\_\_\_\_ A POSITION \_\_\_\_\_

## VACUUM TEST CERTIFICATE

### START OF VACUUM TEST

DATE \_\_\_\_\_ TIME \_\_\_\_\_ VACUUM \_\_\_\_\_

### END OF VACUUM TEST

DATE \_\_\_\_\_ TIME \_\_\_\_\_ VACUUM \_\_\_\_\_

THE ABOVE SYSTEM HAD A WITNESSED VACUUM PULLED DOWN TO 4 mBar AND MAINTAINED FOR A PERIOD OF 2 HOURS WITHOUT MORE THAN A 1.0 mBar RISE IN PRESSURE.

INSTRUMENT USED: KENT/MOORE. 040362/25 CALABRATED: 23/11/2014

INSTRUMENT SERIAL: FTEK-043. CERTIFICATE No. FT0043I. NEXT DUE 23/11/2015.

ENGINEERS SIGNATURE \_\_\_\_\_ CUSTOMERS SIGNATURE \_\_\_\_\_  
F-GAS QUALIFICATION \_\_\_\_\_ C&G 2079 PART 1 \_\_\_\_\_ PRINT NAME \_\_\_\_\_ A NAME \_\_\_\_\_  
SIGNATURE DATE \_\_\_\_\_ 00/01/1900 \_\_\_\_\_ CUSTOMERS JOB TITLE \_\_\_\_\_ A POSITION \_\_\_\_\_

# PPM REPORT - RECIP. CHILLERS

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION		SHEET NUMBER <b>00000</b>
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO	CLIENT ASSET NUMBER <b>00000</b>	
REASON FOR VISIT A VISIT		F-GAS QUALIFICATION C&G 2079 PART 1		
JOB NUMBER	A JOB	MANUFACTURER A MANUFACTURER	MODEL A MODEL NUMBER	
PLANT LOCATION	A LOCATION	SERIAL No. A SERIAL NUMBER	YEAR INSTALLED 01/01/1980	
PLANT REFERENCE	A PLANT REFERENCE	REFRIGERANT TYPE R22	QUANTITY (KG) 240.0 KG	
COMPRESSOR MANUFACTURER:	COPELAND	COMPRESSOR OIL TYPE:	EAL ARTIC 22CC	OIL VOLUME: 2 OFF 7.5 L
COMPRESSOR 1 MODEL:	D8DJ/6000/DWM/D	SERIAL:	991 71640	HRS RUN: N/A
COMPRESSOR 2 MODEL:	D8DJ/6000/DWM/D	SERIAL:	991 71674	HRS RUN: N/A
COMPRESSOR 3 MODEL:	N/A	SERIAL:	N/A	HRS RUN: N/A
COMPRESSOR 4 MODEL:	N/A	SERIAL:	N/A	HRS RUN: N/A

**BOX CODES**    YES    NO    GOOD    FAIR    POOR    BAD    NOT APPLICABLE

<b>COMPRESSOR Min/Maj</b>	
<input type="checkbox"/> G	Check Oil Level
<input type="checkbox"/> GG	Check Oil Heater Operation
<input type="checkbox"/> GG	Check Compressor Pumping
<input type="checkbox"/> GG	Pump Down Test
<input type="checkbox"/> G	Condition of Oil (One Shot Test)
<b>COMPRESSOR Maj</b>	
<input type="checkbox"/> N	Check Big Ends
<input type="checkbox"/> N	Check Sump for Metal
<input type="checkbox"/> N	Oil Sample Taken (Lab Test)
<input type="checkbox"/> N	Swab Sump
<input type="checkbox"/> N	Suction Valves & Springs
<input type="checkbox"/> N	Discharge Valve & Springs
<input type="checkbox"/> N	Check Cylinder Sleeves
<input type="checkbox"/> N	Check Suction Strainer
<input type="checkbox"/> Y	Check Oil Strainer
<input checked="" type="checkbox"/> *1 G	Check Unloader Operation
<b>AIR CONDENSERS Min/Maj</b>	
<input type="checkbox"/> G	Condition of Coils
<input type="checkbox"/> G	Check Fans
<b>AIR CONDENSERS Maj</b>	
<input type="checkbox"/> Y	Condenser Coils Brushed
<input type="checkbox"/> N	Condenser Chemical Cleaned
<b>S &amp; TUBE CONDENSERS Maj</b>	
<input type="checkbox"/> N/A	Remove End Covers
<input type="checkbox"/> N/A	Condition of Tubes
<input type="checkbox"/> N/A	Condition of Water Boxes
<input type="checkbox"/> N/A	Check for Water Leaks
<input type="checkbox"/> N/A	Check Water Valve Operation
<b>CONTROL PANELS Min/Maj</b>	
<input type="checkbox"/> G	Check Main Wiring
<input type="checkbox"/> G	Check Main Controller
<input type="checkbox"/> G	Door Seals, Hinges & Latches
<input type="checkbox"/> G	Load / Unload of Compressor
<input type="checkbox"/> GG	Check Compressor Contactors
<input type="checkbox"/> Y	Check & Tighten Connection
<input type="checkbox"/> G	Check Fan O/L
<input type="checkbox"/> G	Check Timer Sequences
<input type="checkbox"/> G	Check Electrical Connections
240 V	L1 Phase Volts to Earth
233 V	L2 Phase Volts to Earth
233 V	L3 Phase Volts to Earth

<b>CONTROL PANELS Min/Maj</b>	
Standard	Micro
25.0 BarG	N/A
2.5 BarG	N/A
N/A	N/A
0.7 BarD	N/A
N/A	3.0 Deg C
25.2 BarG	Actual H.P Cut-Out Pressure
<input type="checkbox"/> G	Test Chilled Water Flow Switch
<input type="checkbox"/> N/A	Test Condenser Water Flow Switch
12.0 Deg C	Temp Control S.P 1
1.5 Deg C	Temp Control D.B/Range 1
N/A	Temp Control S.P 2
1.0 Deg C	Temp Control D.B/Range 2
-4.0 Deg C	Low Ambient Temp C/O
45.0 Deg C	High Ambient Temp C/O
14.0 BarG	Condenser Fan S.P
2.0 BarG	Condenser Fan Range
<input type="checkbox"/> G	Inverter Condition
<input type="checkbox"/> N/A	High Pressure Force Unload
<b>UNIT CONDITION Min/Maj</b>	
<input type="checkbox"/> G	Check Panels
<input type="checkbox"/> G	Check Paintwork
<input type="checkbox"/> G	Check Insulation
<input type="checkbox"/> G	Check Pipework
<input type="checkbox"/> G	Check Solenoid Valves
DRY	N/A
N/A	N/A
<input type="checkbox"/> G	Check Vibration Isolators
NO BINDERS	Evaporator Water Box P.D
<input type="checkbox"/> N/A	Condenser Water Box P.D
<b>CALIBRATION CHECKS Min/Maj</b>	
<input type="checkbox"/> G	Check Oil Temp Sensor/s
<input type="checkbox"/> G	Check Ambient Sensor
<input type="checkbox"/> G	Check Chilled Water Sensor/s
<input type="checkbox"/> N/A	Check Condenser Water Sensor/s
<input type="checkbox"/> G	Check EEV Control
<input type="checkbox"/> N/A	Check S1 Sensor
<input type="checkbox"/> G	Check S2 Sensor
<input type="checkbox"/> G	Check LP Transducers
<input type="checkbox"/> G	Check HP Transducers
<input type="checkbox"/> N/A	Check OP Transducers

<b>F-GAS REFRIGERANT CHECKS Min/Maj</b>	
<input type="checkbox"/> GG	Check Refrigerant Charge
<input type="checkbox"/> GG	Carry Out Leak Test with Electronic Leak Detector
<input type="checkbox"/> N/N	Leaks Found / Repaired
<input type="checkbox"/> GG	Check Pressure Relief Valves
<input type="checkbox"/> GG	Check Pressure Relief Valve Vent Line
<input checked="" type="checkbox"/> *4	01/06/2013 PRV's Five (5) Year Anniversary
<input type="checkbox"/> N/A	Check Fixed Leak Detection System
<input type="checkbox"/> N	Are There Health & Safety Risks

### OPERATION CHECKS Min/Maj

Comp #1	Comp #2	Comp #3	Comp #4	
				Evap Pressure
				Cond Pressure
				Oil Pressure
				Chld Water ON
				Chld Water OFF
				Cond Water ON
				Cond Water OFF
				Ambient
				Compressor Amps
				Compressor Load
				Oil Temp
				EEV STEP

### OPERATION CHECKS Maj

System #1	System #2	System #3	System #4	
10.1 T-Sat C				Evap Tsat (Dew)
				Suction Temp
-10.1 Deg K	0.0 Deg K	0.0 Deg K	0.0 Deg K	Suct Superheat
38.8 T-Sat C				Cond Tsat (Bubble)
				Discharge Temp
-38.8 Deg K	0.0 Deg K	0.0 Deg K	0.0 Deg K	Disch Superheat
				Liquid Line Temp
38.8 Deg K	0.0 Deg K	0.0 Deg K	0.0 Deg K	Subcooling

### MOTOR CHECKS Maj

System #1	System #2	System #3	System #4	
<input type="checkbox"/> G	<input type="checkbox"/> G	<input type="checkbox"/> N/A	<input type="checkbox"/> N/A	Compressors
<input type="checkbox"/> N/A	<input type="checkbox"/> N/A	<input type="checkbox"/> N/A	<input type="checkbox"/> N/A	Control ELCB Test
<input type="checkbox"/> G	<input type="checkbox"/> N/A	<input type="checkbox"/> N/A	<input type="checkbox"/> N/A	Cond Fans 1-4
<input type="checkbox"/> N/A	<input type="checkbox"/> N/A	<input type="checkbox"/> N/A	<input type="checkbox"/> N/A	Cond Fans 5-8
<input type="checkbox"/> N				Chiller Print-Out Taken
<input checked="" type="checkbox"/> N				<b>IS FURTHER WORK NEEDED. (Identify Below)</b>

\* NO FAULTS TO REPORT

ENGINEER SIGNATURE: \_\_\_\_\_ CUSTOMERS SIGNATURE: \_\_\_\_\_ DATE: 00/01/1900



# PPM REPORT - SCREW CHILLERS

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION		SHEET NUMBER <b>00000</b>	
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO	CLIENT ASSET NUMBER <b>00000</b>		
REASON FOR VISIT A VISIT		F-GAS QUALIFICATION C&G 2079 PART 1			
JOB NUMBER A JOB	MANUFACTURER A MANUFACTURER	MODEL	A MODEL NUMBER		
PLANT LOCATION A LOCATION	SERIAL No. A SERIAL NUMBER	YEAR INSTALLED	01/01/1980		
PLANT REFERENCE A PLANT REFERENCE	REFRIGERANT TYPE R22	QUANTITY (KG)	240.0 KG		
COMPRESSOR MANUFACTURER: DAIKIN		COMPRESSOR OIL TYPE: DAPHNE FVC68D		OIL VOLUME:	2 OFF 20L
COMPRESSOR 1 MODEL: EZHC9WSGYE	SERIAL: 7311020	HRS RUN:	20020 (80H Δ PPM)	STARTS:	NOT MONITORED
COMPRESSOR 2 MODEL: EZHC9WSGYE	SERIAL: 7311021	HRS RUN:	19138 (0H Δ PPM)	STARTS:	NOT MONITORED
COMPRESSOR 3 MODEL: N/A	SERIAL: N/A	HRS RUN:	N/A	STARTS:	N/A
COMPRESSOR 4 MODEL: N/A	SERIAL: N/A	HRS RUN:	N/A	STARTS:	N/A

**BOX CODES**    Y YES    N NO    G GOOD    F FAIR    P POOR    B BAD    N/A NOT APPLICABLE

<b>COMPRESSOR Min/Maj</b>	
GG	Check Oil Level
GG	Check Oil Heater Operation
GG	Check Compressor Pumping
GG	Pump Down Test
GG	Check Unloader Operation
YY	20K Hours Inspection Required
<b>COMPRESSOR Maj</b>	
<input type="checkbox"/>	Replace Internal Oil Filter
<b>OIL SEPARATOR Min/Maj</b>	
NN	Oil Sample Test (One Shot)
N/A	Oil Separator Level
N/A	Check Heater Operation
<b>OIL SEPARATOR Maj</b>	
<input type="checkbox"/>	Oil Sample Taken (Lab Test)
<input type="checkbox"/>	Replace External Oil Filter
<b>ECONOMISER Min/Maj</b>	
N/A	Check TX Valve Operation
N/A	Check Solenoid Operation
N/A	Check Liquid Level Control
<b>LIQUID INJECTION Min/Maj</b>	
GG	Check Injection Valve Operation
<b>AIR CONDENSERS Min/Maj</b>	
GG	Condition of Coils
GG	Check Fans
<b>AIR CONDENSERS Maj</b>	
<input type="checkbox"/>	Condenser Coils Brushed
<input type="checkbox"/>	Condenser Chemical Cleaned
<b>S &amp; T CONDENSERS Maj</b>	
N/A	Remove End Covers
N/A	Condition of Tubes
N/A	Condition of Water Boxes
N/A	Check for Water Leaks
<b>CONTROL PANELS Min/Maj</b>	
G	Check Main Wiring
B	Check Main Controller
G	Door Seals, Hinges & Latches
G	Load / Unload of Compressor
Y	Chiller Print-Out Taken

<b>CONTROL PANELS Min/Maj</b>		
GG	Check Compressor Contactors	
Y	Check & Tighten Connection	
GG	Check Fan O/L	
G	Check Timer Sequences	
G	Check Electrical Connections	
GG	Check Cond Fan Voltage Regulator	
Standard	Micro	
25.5 BarG	25.0 BarG	H.P Cut-Out
1.5 BarG	3.0 BarG	L.P Cut-Out
N/A	N/A	Pumpdown C/O
N/A	5.0 BarD	Oil Press C/O
N/A	3.0 Deg C	LTL Cut-Out
UNTESTED	Actual H.P Cut-Out Pressure	
GG	Test Flow Switches	
12.0 Deg C	Temp Control S.P	
1.0 Deg C	Temp Control D.B/Range	
-5.0 Deg C	Low Ambient Temp C/O	
45.0 Deg C	High Ambient Temp C/O	
14.0 BarG	Condenser Fan S.P	
6.0 BarG	Condenser Fan Range	
21.5 BarG	High Pressure Force Unload	
<b>UNIT CONDITION Min/Maj</b>		
G	Check Panels, Paintwork & AV Mounts	
G	Check Pipework & Insulation	
G	Check Solenoid Valves	
G	Check Motorised Shut-off Valves	
G	Door Seals, Hinges & Latches	
DRY	DRY	Site Glass Cond.
40.0 KPaD	Evaporator Water Box P.D	
N/A	Condenser Water Box P.D	
NOT TESTED	Glycol CW / CondW	
<b>SENSOR CALIBRATION Min/Maj</b>		
G	Check Ambient Sensor	
GG	Check Chilled Water Sensor/s	
N/A	Check Condenser Water Sensor/s	
N/A	Check Oil Temperature Sensors	
-/G	Check EEV S1 / S2 Sensors	
GG	Check L.P Transducer/s	
GG	Check H.P Transducer/s	
N/A	Check Oil Pressure Transducer/s	
N/A	Check Side Load Pressure Transducer/s	
G	Check Safety Flow Switch/s / Interlocks	

<b>F-GAS REFRIGERANT CHECKS Min/Maj</b>				
GG	Check Refrigerant Charge			
GG	Carry Out Leak Test with Electronic Leak Detector			
N/N	Leaks Found / Repaired			
GG	Check Pressure Relief Valves			
GG	Check Pressure Relief Valve Vent Line			
01/06/2013	PRV's Five (5) Year Anniversary			
N/A	Check Fixed Leak Detection System			
N	Are There Health & Safety Risks			
<b>OPERATION CHECKS Min/Maj</b>				
System A	System B	System #3	System #4	
184.1 KPaG	N/A	N/A	N/A	Evap Pressure
547.5 KPaG	N/A	N/A	N/A	Cond Pressure
325.5 KPaD	N/A	N/A	N/A	Oil Differential
24.8 KPaD	N/A	N/A	N/A	Oil Filter Differential
8.6 DegC		N/A		Chld Water ON
7.8 DegC		N/A		Chld Water OFF
15.3 DegC		N/A		Cond Water ON
19.2 DegC		N/A		Cond Water OFF
12.7 DegC		N/A		Ambient
152.0 Amps	N/A	N/A	N/A	Compressor Amps
21.8 DegC	N/A	N/A	N/A	Oil Temp
N/A	N/A	N/A	N/A	EconTemp Diff.
N/A	N/A	N/A	N/A	EEV Position
88.0%	N/A	N/A	N/A	Slide Valve Position
<b>OPERATION CHECKS Maj</b>				
System #1	System #2	System #3	System #4	
-0.8 C Tsat		N/A	N/A	Evap Tsat
5.8 Deg C		N/A	N/A	Suction Temp
6.6 Deg K	0.0 Deg K	N/A	N/A	Suct Superheat
24.1 C Tsat		N/A	N/A	Cond Tsat
34.3 Deg C		N/A	N/A	Discharge Temp
10.2 Deg K	0.0 Deg K	N/A	N/A	Disch Superheat
23.8 Deg C		N/A	N/A	Liquid Line Temp
0.3 Deg K	0.0 Deg K	N/A	N/A	Subcooling
N/A	N/A	N/A	N/A	Winding Thermistor
<b>MOTOR CHECKS Maj</b>				
System #1	System #2	System #3	System #4	
G	G	N/A	N/A	Comp. Windings
				Cond Fans 1-4
				Cond Fans 5-8
				Cond Fans 9-12
N	<b>IS FURTHER WORK NEEDED. (Identify Below)</b>			

**FAULTS FOUND:**  
\* NO FAULTS TO REPORT

ENGINEER SIGNATURE: \_\_\_\_\_ CUSTOMERS SIGNATURE: \_\_\_\_\_ DATE: 00/01/1900

# PPM REPORT - INVERTER SCREW CHILLERS

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION		SHEET NUMBER <b>00000</b>	
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO	F-GAS QUALIFICATION C&G 2079 PART 1		CLIENT ASSET NUMBER <b>00000</b>
REASON FOR VISIT A VISIT	MANUFACTURER A MANUFACTURER	MODEL	A MODEL NUMBER		
JOB NUMBER A JOB	SERIAL No. A SERIAL NUMBER	YEAR INSTALLED	01/01/1980		
PLANT LOCATION A LOCATION	REFRIGERANT TYPE R22	QUANTITY (KG)	240.0 KG		
PLANT REFERENCE A PLANT REFERENCE	CLG LOAD SERVED A COOLING LOAD SERVED				
COMPRESSOR MANUFACTURER: CARRIER (ThermaCom)	COMPRESSOR OIL TYPE: CARRIER SW220	OIL VOLUME:	40 LTR + 20 LTR		
COMPRESSOR 1 MODEL: 06NA2300S5N-A00	SERIAL: TZ681649 (REBUILD)	HRS RUN: 18567	STARTS:	45315	
COMPRESSOR 2 MODEL: 06NA2300S5NA-A00	SERIAL: TZ6801423 (REBUILD)	HRS RUN: 18051	STARTS:	45366	
COMPRESSOR 3 MODEL: 06NA2300S5NC-A00	SERIAL: TZ6801648 (REBUILD)	HRS RUN: 18748	STARTS:	48288	
COMPRESSOR 4 MODEL: N/A	SERIAL: N/A	HRS RUN: N/A	STARTS:	N/A	

**BOX CODES**  Y YES  N NO  G GOOD  F FAIR  P POOR  B BAD  N/A NOT APPLICABLE

### COMPRESSOR Min/Maj

GG	Check Oil Level
N/A	Check Oil Heater Operation
GGG	Check Compressor Pumping
GGG	Pump Down Test
NN	20K Hours Inspection Required

### COMPRESSOR Maj

	Replace Internal Oil Filter
--	-----------------------------

### OIL SEPARATOR Min/Maj

GG	Oil Sample Test (One Shot)
GG	Oil Separator Level
GG	Check Heater Operation

### OIL SEPARATOR Maj

	Oil Sample Taken (Lab Test)
	Replace External Oil Filter

### ECONOMISER Min/Maj

N/A	Check FEED Valve Operation
N/A	Check Solenoid Operation
N/A	Check Liquid Level Control
N/A	Check DRAIN Valve Operation

### LIQUID INJECT Min/Maj

GGG	Check Injection Valve Operation
-----	---------------------------------

### \*1 AIR CONDENSERS Min/Maj

FF	Condition of Coils
GG	Check Fans

### AIR CONDENSERS Maj

	Condenser Coils Brushed
	Condenser Chemical Cleaned

### S & T CONDENSERS Maj

N/A	Remove End Covers
N/A	Condition of Tubes
N/A	Condition of Water Boxes
N/A	Check for Water Leaks

### CONTROL PANELS Min/Maj

*2	G	Check Main Wiring
	B	Check Main Controller
	B	Door Seals, Hinges & Latches
	Y	Chiller Print-Out Taken

### CONTROL PANELS Min/Maj

GGG	Check Compressor Contactors	
Y	Check & Tighten Connection	
GG	Check Fan O/L	
G	Check Timer Sequences	
*3	B	Check Electrical Connections
N/A	Check Compressor Soft Starters	

Standard	Micro	
21.8 BarG	21.0 BarG	H.P Cut-Out
N/A	0.5 BarG	L.P Cut-Out
N/A	0.5 BarG	Pumpdown C/O
DP-OP>540KPaG : 6 SEC		Oil Press C/O
N/A	2.1 Deg C	LTL Cut-Out
UNTESTED		Actual H.P Cut-Out Pressure
*4	G	Test Flow Switches
6.0 Deg C		Temp Control S.P
1.0 Deg C		Temp Control D.B/Range
-18.0 Deg C		Low Ambient Temp C/O
45.0 Deg C		High Ambient Temp C/O
14.0 BarG		Condenser Fan S.P
6.0 BarG		Condenser Fan Range
18.0 BarG		High Pressure Force Unload

### UNIT CONDITION Min/Maj

G	Check Panels & Paintwork		
G	Check Insulation		
G	Check Pipework		
G	Check Solenoid Valves		
	DRY	DRY	Sight Glass Cond
G	Check Vibration Isolators		
N/A	Check Oil Sensors		
G	Check Ambient Sensor		
GG	Check Chilled Water Sensor/s		
N/A	Check Condenser Water Sensor/s		
GG	Check EEV Control		
N/A	Check S1 Sensor		
GG	Check S2 Sensor		
GG	Check LP Transducers		
GG	Check HP Transducers		
GG	Check OP Transducers		
*5	50 KPaD	Evaporator Water Box P.D	
	N/A	Condenser Water Box P.D	
	NOT TESTED	Glycol CW / CondW	

### F-GAS REFRIGERANT CHECKS Min/Maj

GGG	Check Refrigerant Charge	
GGG	Carry Out Leak Test with Electronic Leak Detector	
N/N	Leaks Found / Repaired	
GGG	Check Pressure Relief Valves	
GGG	Check Pressure Relief Valve Vent Line	
	01/06/2014	PRV's Five (5) Year Anniversary
N/A	Check Fixed Leak Detection System	
Y	Are There Health & Safety Risks	

### OPERATION CHECKS Min/Maj

System #1	System #2	System #3	System #4	
2.81 BarG	2.12 BarG	2.15 BarG	N/A	Evap Pressure
2.8 BarG	8.6 BarG	8.8 BarG	N/A	Cond Pressure
2.8 BarG	7.7 BarG	7.7 BarG	N/A	Oil Pressure
	8.2 Deg C		N/A	Chld Water ON
	5.1 Deg C		N/A	Chld Water OFF
	N/A		N/A	Cond Water ON
	N/A		N/A	Cond Water OFF
		16.2 Deg C		Ambient
0.0 Amps	184.0 Amps	196.0 BarG	N/A	Compressor Amps
28.8 Deg C	38.5 Deg C	35.2 BarG	N/A	Oil Temp
OFF	ON	ON	N/A	EconTemp Pressure
0.0%	88.1%	71.3%	N/A	Feed Valve Position
0.3%	5.8%	14.5%	N/A	Economiser Level
0.0%	50.0%	51.8%	N/A	Drain Valve Position
0.0%	85.2%	100.0%	N/A	Compressor Loading

### OPERATION CHECKS Maj

System #1	System #2	System #3	System #4	
-	4.5 Deg K	3.5 Deg K	N/A	Suct Superheat
-	13.0 Deg K	11.3 Deg K	N/A	Disch Superheat
-	7.2 Deg K	7.5 Deg K	N/A	Subcooling @ 100%
	160.2 HZ		N/A	VSD Frequency
	542.0 VDC		N/A	DC Bus Voltage
	40.0 Deg C		N/A	Backplate Temp
	28.9 Deg C		N/A	Internal Ambient
52.3 Deg C	38.3 Deg C	43.1 Deg C	N/A	Winding Thermistor

### MOTOR CHECKS Maj

System #1	System #2	System #3	System #4	
G	G	G	N/A	Comp. Windings
G	G	G	G	Cond Fans 1-4
G	G	G	G	Cond Fans 5-8
G	G	G	G	Cond Fans 9-12

**N IS FURTHER WORK NEEDED. (Identify Below)**

### FAULTS FOUND:

\*1 NO FAULTS FOUND

ENGINEER SIGNATURE: \_\_\_\_\_ CUSTOMERS SIGNATURE: \_\_\_\_\_ DATE: 00/01/1900

# PPM REPORT - SCROLL CHILLERS

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION		SHEET NUMBER <b>00000</b>	
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO	CLIENT ASSET NUMBER <b>00000</b>		
REASON FOR VISIT A VISIT	MANUFACTURER A MANUFACTURER	F-GAS QUALIFICATION C&G 2079 PART 1	MODEL	A MODEL NUMBER	
JOB NUMBER A JOB	SERIAL No. A SERIAL NUMBER	YEAR INSTALLED	01/01/1980		
PLANT LOCATION A LOCATION	REFRIGERANT TYPE R22	QUANTITY (KG)	240.0 KG		
PLANT REFERENCE A PLANT REFERENCE	CLG LOAD SERVED	A COOLING LOAD SERVED			
COMPRESSOR MANUFACTURER: COPELAND	COMPRESSOR OIL TYPE: ICI EMCARATE RL32CF	OIL VOLUME: 2 OFF 4.1 LTRS			
COMPRESSOR A1 MODEL: ZR16M3E-TWD-551	SERIAL: RE1400208437	HRS RUN: 0	HRS RUN DIFF: 0	STARTS: UNLOGGED	
COMPRESSOR A2 MODEL: N/A	SERIAL: RE1400207352	HRS RUN: 0	HRS RUN DIFF: 0	STARTS: UNLOGGED	
COMPRESSOR A3 MODEL: N/A	SERIAL: RE1400208406	HRS RUN: 0	HRS RUN DIFF: 0	STARTS: UNLOGGED	
COMPRESSOR A4 MODEL: N/A	SERIAL: RE1400208623	HRS RUN: 0	HRS RUN DIFF: 0	STARTS: UNLOGGED	
COMPRESSOR B1 MODEL: ZR16M3E-TWD-551	SERIAL: N/A	HRS RUN: N/A	HRS RUN DIFF: N/A	STARTS: N/A	
COMPRESSOR B2 MODEL: N/A	SERIAL: N/A	HRS RUN: N/A	HRS RUN DIFF: N/A	STARTS: N/A	
COMPRESSOR B3 MODEL: N/A	SERIAL: N/A	HRS RUN: N/A	HRS RUN DIFF: N/A	STARTS: N/A	
COMPRESSOR B4 MODEL: N/A	SERIAL: N/A	HRS RUN: N/A	HRS RUN DIFF: N/A	STARTS: N/A	

**BOX CODES**    Y YES    N NO    G GOOD    F FAIR    P POOR    B BAD    N/A NOT APPLICABLE

**SYS A COMP Min/Maj**

G	Check Oil Level
N/A	Check Oil Heater Operation
G	Check Compressor Pumping
N/A	Pump Down Test
N/A	Check Starting Bypass Operation
N/A	Condition of Balance Lines
N	Excessive Vibration
G	Condition of Oil (One Shot Test)

**SYS B COMP Min/Maj**

G	Check Oil Level
N/A	Check Oil Heater Operation
G	Check Compressor Pumping
N/A	Pump Down Test
N/A	Check Starting Bypass Operation
N/A	Condition of Balance Lines
N	Excessive Vibration
G	Condition of Oil (One Shot Test)

**SYS A & B COMP Maj**

NN	Oil Sample to Lab
GG	Electrical Terminal Box
N/A	IC Card Operation

**AIR CONDENSERS Min/Maj**

GG	Condition of Coils
GGG	Check Fans

**AIR CONDENSERS Maj**

Y	Condenser Coils Brushed
N	Condenser Chemical Cleaned

**S & T CONDENSERS Maj**

N/A	Remove End Covers
N/A	Condition of Tubes
N/A	Condition of Water Boxes
N/A	Check for Water Leaks

**CONTROL PANELS Min/Maj**

G	Check Main Wiring
G	Check Main Controller
G	Door Seals, Hinges & Latches
N/A	Load / Unload of Compressor
N	Chiller Print-Out Taken

**CONTROL PANELS Min/Maj**

GG	Check Compressor Contactors
Y	Check & Tighten Connection
G	Check Fan O/L
G	Check Timer Sequences
G	Check Electrical Connections
N/A	Check Compressor Soft Starters
Standard      Micro	
25.0 BarG	N/A      H.P Cut-Out
0.5 BarG	N/A      L.P Cut-Out
N/A	N/A      Pumpdown C/O
N/A	N/A      Oil Press C/O
N/A	3.0 Deg C      LTL Cut-Out
UNTESTED	Actual H.P Cut-Out Pressure
G	Test Flow Switches
9.0 Deg C	Temp Control S.P
1.5 Deg C	Temp Control D.B/Range
N/A	Low Ambient Temp C/O
N/A	High Ambient Temp C/O
N/A	Condenser Fan S.P
N/A	Condenser Fan Range
N/A	High Pressure Force Unload

**UNIT CONDITION Min/Maj**

G	Check Panels, Paintwork & AV Mounts
G	Check Pipework & Insulation
G	Check Solenoid Valves
G	Check Motorised Shut-off Valves
G	Door Seals, Hinges & Latches
DRY	DRY      Site Glass Cond.
40.0 KPaD	Evaporator Water Box P.D
N/A	Condenser Water Box P.D
NOT TESTED	Glycol CW / CondW

**SENSOR CALIBRATION Min/Maj**

G	Check Ambient Sensor
GG	Check Chilled Water Sensor/s
N/A	Check Condenser Water Sensor/s
N/A	Check Oil Temperature Sensors
-/G	Check EEV S1 / S2 Sensors
GG	Check L.P Transducer/s
GG	Check H.P Transducer/s
N/A	Check Oil Pressure Transducer/s
N/A	Check Subcooler Pressure Transducer
G	Check Safety Flow / Interlocks

**F-GAS REFRIGERANT CHECKS Min/Maj**

GG	Check Refrigerant Charge
GG	Carry Out Leak Test with Electronic Leak Detector
N/N	Leaks Found / Repaired
GG	Check Pressure Relief Valves
30/06/2018	PRV's Five (5) Year Anniversary
N/A	Check Pressure Relief Valve Vent Line
N/A	Check Fixed Leak Detection System
N	Are There Health & Safety Risks

**OPERATION CHECKS Min/Maj**

System A		System B		
380.0 KPaG		390.0 KPaG		Evap Pressure
1610.0 KPaG		1560.0 KPaG		Cond Pressure
10.5 Deg C				Chld Water ON
7.3 Deg C				Chld Water OFF
N/A				Cond Water ON
N/A				Cond Water OFF
17.6 Deg C				Ambient
18.5 Amps	N/A	N/A	N/A	System A Amps
17.6 Amps		N/A	N/A	System B Amps
11.9 Deg C		12.5 Deg C		Oil Temp
N/A		N/A		EEV Position
100.0%		100.0%		Stages %

**OPERATION CHECKS Maj**

System A		System B		
				Evap Tsat
				Suction Temp
0.0 Deg K		0.0 Deg K		Suct Superheat
				Cond Tsat
				Discharge Temp
0.0 Deg K		0.0 Deg K		Disch Superheat
				Liquid Line Temp
0.0 Deg K		0.0 Deg K		Subcooling
G	G	N/A	N/A	A Winding Therm
G	G	G	N/A	B Winding Therm

**MOTOR CHECKS Maj**

Comp #1	Comp #2	Comp #3	Comp #4	
0.4 Ohms	N/A	N/A	N/A	SYS A Windings
0.4 Ohms	N/A	N/A	N/A	SYS B Windings
1.1 AMPS 3PH	1.1 AMPS 3PH	1.1 AMPS 3PH	N/A	Cond Fans 1-4
N/A	N/A	N/A	N/A	Cond Fans 5-8
N/A	N/A	N/A	N/A	Cond Fans 9-12
N	<b>IS FURTHER WORK NEEDED. (Identify Below)</b>			

**FAULTS FOUND:**  
**\*1 NO OTHER FAULTS TO REPORT.**

ENGINEER SIGNATURE: \_\_\_\_\_ CUSTOMERS SIGNATURE: \_\_\_\_\_ DATE: 00/01/1900



# PPM REPORT - CENTRIFUGAL CHILLERS

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION		SHEET NUMBER <b>00000</b>	
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO	CLIENT ASSET NUMBER <b>00000</b>		
REASON FOR VISIT A VISIT		F-GAS QUALIFICATION C&G 2079 PART 1			
JOB NUMBER A JOB	MANUFACTURER A MANUFACTURER	MODEL A MODEL NUMBER			
PLANT LOCATION A LOCATION	SERIAL No. A SERIAL NUMBER	YEAR INSTALLED 01/01/1980			
PLANT REFERENCE A PLANT REFERENCE	REFRIGERANT TYPE R22	QUANTITY (KG) 240.0 KG			
COMPRESSOR MANUFACTURER: McQUAY. SPEED CODE - AR.	COMPRESSOR OIL TYPE: MOBIL EAL ARCTIC 46	OIL VOLUME: 20 LTRS			
COMPRESSOR 1 MODEL: GEO79 JAR23K OX	SERIAL: 56C0084001	HRS RUN: 36669	STARTS: 28627		

**BOX CODES**  Y YES  N NO  G GOOD  F FAIR  P POOR  B BAD  N/A NOT APPLICABLE

- COMPRESSOR Min/Maj**
- N/A Check Oil Level
  - G Check Oil Heater Operation
  - G Check Compressor Pumping
  - G Check Inlet Guide Vane
  - G Hours Run Inspection Required

- COMPRESSOR Maj**
- Replace Internal Oil Filter/s

- OIL RES Min/Maj**
- N Oil Sample Test (One Shot)
  - 100% Oil Separator Level
  - G Check Heater Operation
  - G Internal Oil Pump Operation
  - N/A External Oil Pump Operation

- OIL RESERVOIR Maj**
- Oil Sample Taken (Lab Test)
  - Replace External Oil Filter

- OIL COOLING Min/Maj**
- G Check TX Valve Operation
  - N/A Check Plate HX Operation

- LIQUID INJECT Min/Maj**
- G Check Injection Valve Operation

- AIR CONDENSERS Min/Maj**
- N/A Condition of Coils
  - N/A Check Fans

- AIR CONDENSERS Maj**
- Condenser Coils Brushed
  - Condenser Chemical Cleaned

- S & T CONDENSERS Maj**
- Remove End Covers
  - Condition of Tubes
  - Condition of Water Boxes
  - G Check for Water Leaks

- CONTROL PANELS Min/Maj**
- G Check Main Wiring
  - G Check Main Controller
  - G Door Seals, Hinges & Latches
  - G Load / Unload of Compressor
  - F Check Compressor Contactors
  - Y Check & Tighten Connection
  - N Chiller Print-Out Taken

**CONTROL PANELS Min/Maj**

- N/A Check Fan O/L
- G Check Timer Sequences
- G Check Electrical Connections
- G Check Comp Soft Starters

Standard	Micro	
14.6 BarG	9.7 BarG	H.P Cut-Out
N/A	1.8 BarG	L.P Cut-Out
N/A	0.1 BarG	Pumpdown C/O
N/A	4.1 BarG	Oil Press C/O
N/A	2.0 Deg C	LTL Cut-Out

UNTESTED	Actual H.P Cut-Out Pressure
8.5 Deg C	Temp Control S.P
1.6 Deg C	Temp Control S.P - C/O
3.0 Deg C	Temp Control S.P + CI
40 Mins	AR Time Strt - Strt
20 Mins	AR Time Stp - Strt
87.0 Deg C	High Disch. Temp C/O
22.0 Deg K	High Suct Temp C/O
115.0 BarG	Winding Temp C/O
100.0%	Current Module S.P
115.0 BarG	Winding Temp C/O
100.0%	Current Module S.P

- UNIT CONDITION Min/Maj**
- F Check Panels & Paintwork
  - F Check Insulation
  - G Check Pipework
  - G Check Solenoid Valves
  - \*4 B Sight Glass Cond
  - G Check Vibration Isolators
  - \*1 30.0 KPaD Evaporator Water Box P.D
  - \*1 65.0 KPaD Condenser Water Box P.D
  - N/A Glycol CW / CondW

- SENSOR CALIBRATION Min/Maj**
- N/A Check Ambient Sensor
  - GG Check Chilled Water Sensor/s
  - GG Check Condenser Water Sensor/s
  - N/A Check EEV S1 Sensor
  - N/A Check EEV S2 Sensor
  - GG Check L.P Transducer/s
  - G Check H.P Transducer/s
  - G Check Oil Pressure Transducer/s
  - G/G Check Safety Flow Switch/s / Interlocks

- F-GAS REFRIGERANT CHECKS Min/Maj**
- \*4 B Check Refrigerant Charge
  - Y Carry Out Leak Test with Electronic Leak Detector
  - \*4 Y/N Leaks Found / Repaired
  - \*2 B Check Pressure Relief Valves
  - \*2 30/06/2013 PRV's Five (5) Year Anniversary
  - \*3 B Check Pressure Relief Valve Vent Line
  - G Check Fixed Leak Detection System
  - Y Are There Health & Safety Risks

**OPERATION CHECKS Min/Maj**

System #1	System #2	System #3	System #4	
-	N/A	N/A	N/A	Evap Pressure
-	N/A	N/A	N/A	Cond Pressure
-	N/A	N/A	N/A	Oil Pressure
-	N/A	N/A	N/A	Oil Differential
-	N/A	N/A	N/A	Chld Water ON
-	N/A	N/A	N/A	Chld Water OFF
-	N/A	N/A	N/A	Cond Water ON
-	N/A	N/A	N/A	Cond Water OFF
-	N/A	N/A	N/A	Ambient
-	N/A	N/A	N/A	Compressor Amps
-	N/A	N/A	N/A	Oil Temp
-	N/A	N/A	N/A	Oil Clg Temp Diff.
N/A	N/A	N/A	N/A	EEV Position
NO FEEDBACK	N/A	N/A	N/A	IGV Position

**OPERATION CHECKS Maj**

System #1	System #2	System #3	System #4	
				Evap Tsat
				Suction Temp
0.0 Deg K	0.0 Deg K	0.0 Deg K	0.0 Deg K	Suct Superheat
				Cond Tsat
				Discharge Temp
0.0 Deg K	0.0 Deg K	0.0 Deg K	0.0 Deg K	Disch Superheat
				Liquid Line Temp
0.0 Deg K	0.0 Deg K	0.0 Deg K	0.0 Deg K	Subcooling
-				Winding Thermistor
0.0 Deg C	0.0 Deg C	0.0 Deg C	0.0 Deg C	Cond Approach
0.0 Deg C	0.0 DegC	0.0 DegC	0.0 DegC	Evap Approach

**MOTOR CHECKS Maj**

System #1	System #2	System #3	System #4	
0.5 Ohms	N/A	N/A	N/A	Comp. Windings
N/A	N/A	N/A	N/A	Cond Fans 1-4
N/A	N/A	N/A	N/A	Cond Fans 5-8
N/A	N/A	N/A	N/A	Cond Fans 9-12

Y **IS FURTHER WORK NEEDED. (Identify Below)**

**FAULTS FOUND:**  
\*1 NO FAULTS FOUND

ENGINEER SIGNATURE: \_\_\_\_\_ CUSTOMERS SIGNATURE: \_\_\_\_\_ DATE: 00/01/1900

# PPM REPORT - TURBOCOR CHILLERS

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION		SHEET NUMBER <b>00000</b>	
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO	F-GAS QUALIFICATION C&G 2079 PART 1		CLIENT ASSET NUMBER <b>00000</b>
REASON FOR VISIT A VISIT	MANUFACTURER A MANUFACTURER	MODEL	A MODEL NUMBER		
JOB NUMBER A JOB	SERIAL No. A SERIAL NUMBER	YEAR INSTALLED	01/01/1980		
PLANT LOCATION A LOCATION	REFRIGERANT TYPE R22	QUANTITY (KG)	240.0 KG		
PLANT REFERENCE A PLANT REFERENCE	CLG LOAD SERVED	A COOLING LOAD SERVED			
COMPRESSOR 1 MODEL: TT330-H6-1-ST-E-0-CE	PART No: 194120	SERIAL: 123475130	CAPACITOR EXP.	30/01/2018	
COMPRESSOR 2 MODEL: TT330-H6-1-ST-E-0-CE	PART No: 194120	SERIAL: 123485120	CAPACITOR EXP.	30/01/2018	
COMPRESSOR 3 MODEL: N/A	PART No: N/A	SERIAL: N/A	CAPACITOR EXP.	N/A	
COMPRESSOR 4 MODEL: N/A	PART No: N/A	SERIAL: N/A	CAPACITOR EXP.	N/A	

**BOX CODES**  Y YES  N NO  G GOOD  F FAIR  P POOR  B BAD  N/A NOT APPLICABLE

<p><b>COMPRESSOR Min/Maj</b></p> <p>GGG Check Covers are Secure</p> <p>GGG Check Electrical Harnesses</p> <p>Compressor Pumping</p> <p><b>LIQUID INJECT Min/Maj</b></p> <p>GGG Check Injection Valve Operation</p> <p><b>SUBCOOLER Min/Maj</b></p> <p>N/A Check TX Valve Operation</p> <p>N/A Check Plate HX Operation</p> <p><b>AIR CONDENSERS Min/Maj</b></p> <p>*1 FF Condition of Coils</p> <p>GG Check Fans</p> <p><b>AIR CONDENSERS Maj</b></p> <p>YY Condenser Coils Brushed</p> <p>NN Condenser Chemical Cleaned</p> <p><b>S &amp; T CONDENSERS Maj</b></p> <p>N/A Remove End Covers</p> <p>N/A Condition of Tubes</p> <p>N/A Condition of Water Boxes</p> <p>N/A Check for Water Leaks</p> <p><b>CONTROL PANELS Min/Maj</b></p> <p>G Check Main Wiring</p> <p>G Check Electrical Connections</p> <p>G Check Compressor buss Bars</p> <p>GGG Check Inductor &amp; Harmonic Filter</p> <p>G Check Main Controller</p> <p>N/A Check EEV Driver Interface</p> <p>G Check EEV Battery Pack</p> <p>G Check Fan O/L</p> <p>G Check Cond Fan Voltage Reg</p> <p>7.0 Deg C Temp Control S.P</p> <p>1.6 Deg C Temp Control Range</p> <p>11.0 Deg C Seq. / BMS Control S.P</p> <p><b>SAFETY LIMITS Min/Maj</b></p> <table border="1"> <tr> <th>Micro</th> <th>Manual</th> <th></th> </tr> <tr> <td>14.6 BarG</td> <td>9.7 BarG</td> <td>H.P Cut-Out</td> </tr> <tr> <td>N/A</td> <td>1.8 BarG</td> <td>L.P Cut-Out</td> </tr> <tr> <td>2.0 Deg C</td> <td>LTL</td> <td>Cut-Out</td> </tr> <tr> <td>UNTESTED</td> <td></td> <td>Actual H.P Cut-Out Press</td> </tr> <tr> <td>80.0 Deg C</td> <td></td> <td>Cavity Temp Alarm</td> </tr> <tr> <td>75.0 Deg C</td> <td></td> <td>Inverter Temp Limit</td> </tr> <tr> <td>75.0 Deg C</td> <td></td> <td>SCR Temp Limit</td> </tr> </table>	Micro	Manual		14.6 BarG	9.7 BarG	H.P Cut-Out	N/A	1.8 BarG	L.P Cut-Out	2.0 Deg C	LTL	Cut-Out	UNTESTED		Actual H.P Cut-Out Press	80.0 Deg C		Cavity Temp Alarm	75.0 Deg C		Inverter Temp Limit	75.0 Deg C		SCR Temp Limit	<p><b>UNIT CONDITION Min/Maj</b></p> <p>GG Check Panels &amp; Paintwork</p> <p>GG Check Insulation</p> <p>*3 FF Check Pipe work</p> <p>G Check Solenoid Valves</p> <p>G Check Motorised Shut-off Valves</p> <p>Door Seals, Hinges &amp; Latches</p> <p>DRY DRY Site Glass Cond.</p> <p>25.0 KPaD Evaporator Water Box P.D</p> <p>N/A Condenser Water Box P.D</p> <p>NOT TESTED Glycol CW / CondW</p> <p><b>SENSOR CALIBRATION Min/Maj</b></p> <p>G Check Ambient Sensor</p> <p>GG Check Chilled Water Sensor/s</p> <p>N/A Check Condenser Water Sensor/s</p> <p>GG Check Turbocor Temp. Sensors</p> <p>GG Check L.P Transducer/s</p> <p>*4 GG Check H.P Transducer/s</p> <p>G/G Check Safety Flow Switch/s / Interlocks</p> <p><b>F-GAS CHECKS Min / Maj</b></p> <p>GG Check Refrigerant Charge</p> <p>YY Leak Test with Electronic Detector</p> <p>NN Leaks Found / Repaired</p> <p>GG Check Pressure Relief Valves</p> <p>30/01/2018 PRV's Five (5) Year Anniversary</p> <p>N/A Check PRV Vent Line</p> <p>B Check Fixed Leak Detection Syst.</p> <p>Y Are There Health &amp; Safety Risks</p> <p><b>COND FAN MOTOR CHECKS Maj</b></p> <table border="1"> <tr> <td>3.7 A 3PH</td> <td>3.7 A 3PH</td> <td>3.8 A 3PH</td> <td>1-3</td> </tr> <tr> <td>3.8 A 3PH</td> <td>3.8 A 3PH</td> <td>3.7 A 3PH</td> <td>4-6</td> </tr> <tr> <td>3.7 A 3PH</td> <td>3.8 A 3PH</td> <td>3.7 A 3PH</td> <td>7-9</td> </tr> <tr> <td>3.8 A 3PH</td> <td>3.8 A 3PH</td> <td>3.7 A 3PH</td> <td>10-12</td> </tr> <tr> <td>3.7 A 3PH</td> <td>3.7 A 3PH</td> <td>3.7 A 3PH</td> <td>13-15</td> </tr> <tr> <td>3.8 A 3PH</td> <td>3.7 A 3PH</td> <td>3.8 A 3PH</td> <td>16-18</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>19-21</td> </tr> </table> <p><b>SOFTWARE REF Min/Maj</b></p> <table border="1"> <tr> <td>W3000</td> <td>Chiller Software Ref</td> </tr> <tr> <td>CA.15.02 GB</td> <td>Chiller Software Rev</td> </tr> <tr> <td>2.0.2685</td> <td>Turbocor BCM Rev</td> </tr> <tr> <td>25 / 25 / 25</td> <td>Turbocor Config Ver</td> </tr> <tr> <td>1.3.917</td> <td>Turbocor CC Rev</td> </tr> </table>	3.7 A 3PH	3.7 A 3PH	3.8 A 3PH	1-3	3.8 A 3PH	3.8 A 3PH	3.7 A 3PH	4-6	3.7 A 3PH	3.8 A 3PH	3.7 A 3PH	7-9	3.8 A 3PH	3.8 A 3PH	3.7 A 3PH	10-12	3.7 A 3PH	3.7 A 3PH	3.7 A 3PH	13-15	3.8 A 3PH	3.7 A 3PH	3.8 A 3PH	16-18	N/A	N/A	N/A	19-21	W3000	Chiller Software Ref	CA.15.02 GB	Chiller Software Rev	2.0.2685	Turbocor BCM Rev	25 / 25 / 25	Turbocor Config Ver	1.3.917	Turbocor CC Rev	<p><b>OPERATIONAL CONTROL Min/Maj</b></p> <table border="1"> <thead> <tr> <th>Comp #1</th> <th>Comp #2</th> <th>Comp #3</th> <th>Comp #4</th> <th></th> </tr> </thead> <tbody> <tr> <td>90.0%</td> <td>90.0%</td> <td>N/A</td> <td>N/A</td> <td>Loading Demand</td> </tr> <tr> <td>110.0%</td> <td>110.0%</td> <td>N/A</td> <td>N/A</td> <td>Inlet Guide Vane</td> </tr> <tr> <td>249.4 KPaG</td> <td>250.8 KPaG</td> <td>N/A</td> <td>N/A</td> <td>Suction Pressure</td> </tr> <tr> <td>1176.2 KPaG</td> <td>1156.6 KPaG</td> <td>N/A</td> <td>N/A</td> <td>Discharge Pressure</td> </tr> <tr> <td>4.1 Deg C</td> <td>7.7 Deg C</td> <td>N/A</td> <td>N/A</td> <td>Suction Temp</td> </tr> <tr> <td>24.2 Deg C</td> <td>24.4 Deg C</td> <td>N/A</td> <td>N/A</td> <td>Discharge Temp</td> </tr> <tr> <td>60.6 Deg C</td> <td>60.8 Deg C</td> <td>N/A</td> <td>N/A</td> <td>SCR Temp</td> </tr> <tr> <td>49.7 Deg C</td> <td>52.9 Deg C</td> <td>N/A</td> <td>N/A</td> <td>Cavity Temp</td> </tr> <tr> <td>52.5 Deg C</td> <td>50.0 Deg C</td> <td>N/A</td> <td>N/A</td> <td>BMCC Temp</td> </tr> <tr> <td>40.9 Deg C</td> <td>38.8 Deg C</td> <td>N/A</td> <td>N/A</td> <td>Inverter Temp</td> </tr> <tr> <td colspan="2">14.3 Deg C</td> <td colspan="2">N/A</td> <td>Chilled Water On</td> </tr> <tr> <td colspan="2">7.4 Deg C</td> <td colspan="2">N/A</td> <td>Chilled Water Off</td> </tr> <tr> <td colspan="4">2.1 DegC</td> <td>Ambient</td> </tr> <tr> <td colspan="2">N/A</td> <td colspan="2">N/A</td> <td>Cond Water On</td> </tr> <tr> <td colspan="2">N/A</td> <td colspan="2">N/A</td> <td>Cond Water Off</td> </tr> </tbody> </table> <p><b>MAGNETIC BEARING MONITORING Maj</b></p> <table border="1"> <thead> <tr> <th>Comp #1</th> <th>Comp #2</th> <th>Comp #3</th> <th>Comp #4</th> <th></th> </tr> </thead> <tbody> <tr> <td>0.40%</td> <td>0.30%</td> <td>0.30%</td> <td>0.30%</td> <td>Axial Un-Balance</td> </tr> <tr> <td>0.20%</td> <td>1.10%</td> <td>0.20%</td> <td>0.20%</td> <td>Front Radial Unbalance</td> </tr> <tr> <td>0.20%</td> <td>0.60%</td> <td>0.20%</td> <td>0.20%</td> <td>Rear Radial Unbalance</td> </tr> <tr> <td>-0.30 Amps</td> <td>-0.60 Amps</td> <td>-0.60 Amps</td> <td>0.33 Amps</td> <td>Axial Bearing Force</td> </tr> <tr> <td>0.20 Amps</td> <td>0.30 Amps</td> <td>-0.20 Amps</td> <td>0.20 Amps</td> <td>Front X Bearing Force</td> </tr> <tr> <td>0.30 Amps</td> <td>-0.40 Amps</td> <td>0.00 Amps</td> <td>0.20 Amps</td> <td>Front Y Bearing Force</td> </tr> <tr> <td>0.40 Amps</td> <td>0.20 Amps</td> <td>0.30 Amps</td> <td>0.20 Amps</td> <td>Rear X Bearing Force</td> </tr> <tr> <td>0.40 Amps</td> <td>-0.20 Amps</td> <td>0.30 Amps</td> <td>0.20 Amps</td> <td>Rear Y Bearing Force</td> </tr> </tbody> </table> <p><b>COMPRESSOR MAP Min/Maj</b></p> <table border="1"> <thead> <tr> <th></th> <th>Comp #1</th> <th>Comp #2</th> <th>Comp #3</th> <th>Comp #4</th> <th></th> </tr> </thead> <tbody> <tr> <td>44.4 kW</td> <td>39.7 kW</td> <td>N/A</td> <td>N/A</td> <td></td> <td>Power Input</td> </tr> <tr> <td>20017 RPM</td> <td>19543 RPM</td> <td>N/A</td> <td>N/A</td> <td></td> <td>Shaft Speed</td> </tr> <tr> <td>53.1%</td> <td>49.0%</td> <td>N/A</td> <td>N/A</td> <td></td> <td>Efficiency</td> </tr> <tr> <td>2.120</td> <td>2.050</td> <td>N/A</td> <td>N/A</td> <td></td> <td>Compression Ratio</td> </tr> <tr> <td>889 (889 Diff)</td> <td>890 (890 Diff)</td> <td>N/A</td> <td>N/A</td> <td></td> <td>Hours Run</td> </tr> <tr> <td>889 (889 Diff)</td> <td>890 (890 Diff)</td> <td>N/A</td> <td>N/A</td> <td></td> <td>No. Starts</td> </tr> </tbody> </table> <p><b>OPERATION CHECKS Maj</b></p> <table border="1"> <thead> <tr> <th>System #1</th> <th>System #2</th> <th>System #3</th> <th>System #4</th> <th></th> </tr> </thead> <tbody> <tr> <td>1.5 Deg K</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>Suct Superheat</td> </tr> <tr> <td>12.0 Deg K</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>Disch Superheat</td> </tr> <tr> <td>4.5 Deg K</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>Subcooling @ Full Load</td> </tr> <tr> <td>1393</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>EEV Position</td> </tr> <tr> <td>2.4 Deg C</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>Evap Approach</td> </tr> </tbody> </table> <p><b>N IS FURTHER WORK NEEDED.</b></p>	Comp #1	Comp #2	Comp #3	Comp #4		90.0%	90.0%	N/A	N/A	Loading Demand	110.0%	110.0%	N/A	N/A	Inlet Guide Vane	249.4 KPaG	250.8 KPaG	N/A	N/A	Suction Pressure	1176.2 KPaG	1156.6 KPaG	N/A	N/A	Discharge Pressure	4.1 Deg C	7.7 Deg C	N/A	N/A	Suction Temp	24.2 Deg C	24.4 Deg C	N/A	N/A	Discharge Temp	60.6 Deg C	60.8 Deg C	N/A	N/A	SCR Temp	49.7 Deg C	52.9 Deg C	N/A	N/A	Cavity Temp	52.5 Deg C	50.0 Deg C	N/A	N/A	BMCC Temp	40.9 Deg C	38.8 Deg C	N/A	N/A	Inverter Temp	14.3 Deg C		N/A		Chilled Water On	7.4 Deg C		N/A		Chilled Water Off	2.1 DegC				Ambient	N/A		N/A		Cond Water On	N/A		N/A		Cond Water Off	Comp #1	Comp #2	Comp #3	Comp #4		0.40%	0.30%	0.30%	0.30%	Axial Un-Balance	0.20%	1.10%	0.20%	0.20%	Front Radial Unbalance	0.20%	0.60%	0.20%	0.20%	Rear Radial Unbalance	-0.30 Amps	-0.60 Amps	-0.60 Amps	0.33 Amps	Axial Bearing Force	0.20 Amps	0.30 Amps	-0.20 Amps	0.20 Amps	Front X Bearing Force	0.30 Amps	-0.40 Amps	0.00 Amps	0.20 Amps	Front Y Bearing Force	0.40 Amps	0.20 Amps	0.30 Amps	0.20 Amps	Rear X Bearing Force	0.40 Amps	-0.20 Amps	0.30 Amps	0.20 Amps	Rear Y Bearing Force		Comp #1	Comp #2	Comp #3	Comp #4		44.4 kW	39.7 kW	N/A	N/A		Power Input	20017 RPM	19543 RPM	N/A	N/A		Shaft Speed	53.1%	49.0%	N/A	N/A		Efficiency	2.120	2.050	N/A	N/A		Compression Ratio	889 (889 Diff)	890 (890 Diff)	N/A	N/A		Hours Run	889 (889 Diff)	890 (890 Diff)	N/A	N/A		No. Starts	System #1	System #2	System #3	System #4		1.5 Deg K	N/A	N/A	N/A	Suct Superheat	12.0 Deg K	N/A	N/A	N/A	Disch Superheat	4.5 Deg K	N/A	N/A	N/A	Subcooling @ Full Load	1393	N/A	N/A	N/A	EEV Position	2.4 Deg C	N/A	N/A	N/A	Evap Approach
Micro	Manual																																																																																																																																																																																																																																																																				
14.6 BarG	9.7 BarG	H.P Cut-Out																																																																																																																																																																																																																																																																			
N/A	1.8 BarG	L.P Cut-Out																																																																																																																																																																																																																																																																			
2.0 Deg C	LTL	Cut-Out																																																																																																																																																																																																																																																																			
UNTESTED		Actual H.P Cut-Out Press																																																																																																																																																																																																																																																																			
80.0 Deg C		Cavity Temp Alarm																																																																																																																																																																																																																																																																			
75.0 Deg C		Inverter Temp Limit																																																																																																																																																																																																																																																																			
75.0 Deg C		SCR Temp Limit																																																																																																																																																																																																																																																																			
3.7 A 3PH	3.7 A 3PH	3.8 A 3PH	1-3																																																																																																																																																																																																																																																																		
3.8 A 3PH	3.8 A 3PH	3.7 A 3PH	4-6																																																																																																																																																																																																																																																																		
3.7 A 3PH	3.8 A 3PH	3.7 A 3PH	7-9																																																																																																																																																																																																																																																																		
3.8 A 3PH	3.8 A 3PH	3.7 A 3PH	10-12																																																																																																																																																																																																																																																																		
3.7 A 3PH	3.7 A 3PH	3.7 A 3PH	13-15																																																																																																																																																																																																																																																																		
3.8 A 3PH	3.7 A 3PH	3.8 A 3PH	16-18																																																																																																																																																																																																																																																																		
N/A	N/A	N/A	19-21																																																																																																																																																																																																																																																																		
W3000	Chiller Software Ref																																																																																																																																																																																																																																																																				
CA.15.02 GB	Chiller Software Rev																																																																																																																																																																																																																																																																				
2.0.2685	Turbocor BCM Rev																																																																																																																																																																																																																																																																				
25 / 25 / 25	Turbocor Config Ver																																																																																																																																																																																																																																																																				
1.3.917	Turbocor CC Rev																																																																																																																																																																																																																																																																				
Comp #1	Comp #2	Comp #3	Comp #4																																																																																																																																																																																																																																																																		
90.0%	90.0%	N/A	N/A	Loading Demand																																																																																																																																																																																																																																																																	
110.0%	110.0%	N/A	N/A	Inlet Guide Vane																																																																																																																																																																																																																																																																	
249.4 KPaG	250.8 KPaG	N/A	N/A	Suction Pressure																																																																																																																																																																																																																																																																	
1176.2 KPaG	1156.6 KPaG	N/A	N/A	Discharge Pressure																																																																																																																																																																																																																																																																	
4.1 Deg C	7.7 Deg C	N/A	N/A	Suction Temp																																																																																																																																																																																																																																																																	
24.2 Deg C	24.4 Deg C	N/A	N/A	Discharge Temp																																																																																																																																																																																																																																																																	
60.6 Deg C	60.8 Deg C	N/A	N/A	SCR Temp																																																																																																																																																																																																																																																																	
49.7 Deg C	52.9 Deg C	N/A	N/A	Cavity Temp																																																																																																																																																																																																																																																																	
52.5 Deg C	50.0 Deg C	N/A	N/A	BMCC Temp																																																																																																																																																																																																																																																																	
40.9 Deg C	38.8 Deg C	N/A	N/A	Inverter Temp																																																																																																																																																																																																																																																																	
14.3 Deg C		N/A		Chilled Water On																																																																																																																																																																																																																																																																	
7.4 Deg C		N/A		Chilled Water Off																																																																																																																																																																																																																																																																	
2.1 DegC				Ambient																																																																																																																																																																																																																																																																	
N/A		N/A		Cond Water On																																																																																																																																																																																																																																																																	
N/A		N/A		Cond Water Off																																																																																																																																																																																																																																																																	
Comp #1	Comp #2	Comp #3	Comp #4																																																																																																																																																																																																																																																																		
0.40%	0.30%	0.30%	0.30%	Axial Un-Balance																																																																																																																																																																																																																																																																	
0.20%	1.10%	0.20%	0.20%	Front Radial Unbalance																																																																																																																																																																																																																																																																	
0.20%	0.60%	0.20%	0.20%	Rear Radial Unbalance																																																																																																																																																																																																																																																																	
-0.30 Amps	-0.60 Amps	-0.60 Amps	0.33 Amps	Axial Bearing Force																																																																																																																																																																																																																																																																	
0.20 Amps	0.30 Amps	-0.20 Amps	0.20 Amps	Front X Bearing Force																																																																																																																																																																																																																																																																	
0.30 Amps	-0.40 Amps	0.00 Amps	0.20 Amps	Front Y Bearing Force																																																																																																																																																																																																																																																																	
0.40 Amps	0.20 Amps	0.30 Amps	0.20 Amps	Rear X Bearing Force																																																																																																																																																																																																																																																																	
0.40 Amps	-0.20 Amps	0.30 Amps	0.20 Amps	Rear Y Bearing Force																																																																																																																																																																																																																																																																	
	Comp #1	Comp #2	Comp #3	Comp #4																																																																																																																																																																																																																																																																	
44.4 kW	39.7 kW	N/A	N/A		Power Input																																																																																																																																																																																																																																																																
20017 RPM	19543 RPM	N/A	N/A		Shaft Speed																																																																																																																																																																																																																																																																
53.1%	49.0%	N/A	N/A		Efficiency																																																																																																																																																																																																																																																																
2.120	2.050	N/A	N/A		Compression Ratio																																																																																																																																																																																																																																																																
889 (889 Diff)	890 (890 Diff)	N/A	N/A		Hours Run																																																																																																																																																																																																																																																																
889 (889 Diff)	890 (890 Diff)	N/A	N/A		No. Starts																																																																																																																																																																																																																																																																
System #1	System #2	System #3	System #4																																																																																																																																																																																																																																																																		
1.5 Deg K	N/A	N/A	N/A	Suct Superheat																																																																																																																																																																																																																																																																	
12.0 Deg K	N/A	N/A	N/A	Disch Superheat																																																																																																																																																																																																																																																																	
4.5 Deg K	N/A	N/A	N/A	Subcooling @ Full Load																																																																																																																																																																																																																																																																	
1393	N/A	N/A	N/A	EEV Position																																																																																																																																																																																																																																																																	
2.4 Deg C	N/A	N/A	N/A	Evap Approach																																																																																																																																																																																																																																																																	

\*1 NO FAULTS TO REPORT

ENGINEER SIGNATURE: \_\_\_\_\_ CUSTOMERS SIGNATURE: \_\_\_\_\_ DATE: 00/01/1900

# PPM REPORT - SINGLE STAGE ABSORBER

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION		SHEET NUMBER <b>00000</b>
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO		
		F-GAS QUALIFICATION C&G 2079 PART 1		
REASON FOR VISIT A VISIT	MANUFACTURER A MANUFACTURER	MODEL A MODEL NUMBER		
JOB NUMBER A JOB	SERIAL No. A SERIAL NUMBER	YEAR INSTALLED 01/01/1980		
PLANT LOCATION A LOCATION	REFRIGERANT R717 R22	QUANTITY (KG) 240.0 KG		
PLANT REFERENCE A PLANT REFERENCE	CLG LOAD SERVED A COOLING LOAD SERVED			

**BOX CODES**  Y YES  N NO  G GOOD  F FAIR  P POOR  B BAD  N/A NOT APPLICABLE

### VACUUM PUMP Min/Maj

N/A	Check Oil Level / Condition
G	Check Drive Belt
G	Test Vacuum Achieved
1.0 Amps	Motor Current
G	Contactors Condition
52	Hours Run
171	Number Starts

### VACUUM PUMP OIL Maj

	Replace Oil
--	-------------

### ABSORB. CHECKS Min/Maj

N	Motor Rotation Test
0.8 Amps	Motor Current
G	Contactors Condition
4605	Hours Run
491	Number Starts

### ABSORB. CHECKS Maj

Y	Blow Down Refrigerant
N	Take Sample for Analysis

### REFRIG. CHECKS Min/Maj

N	Motor Rotation Test
1.1 Amps	Motor Current
G	Contactors Condition
4306	Hours Run
9001	Number Starts

### REFRIG. CHECKS Maj

	Blow Down to Purify
N	Check Spec Gravity

### CONTROL PANELS Min/Maj

G	Check Main Wiring
G	Check Main Controller
G	Door Seals, Hinges & Latches
G	Sensor Calibration
F	Test Outputs
Y	Test Display
N	Test Gen High Press Switch
Y	Test Low Ref. Lvl Safety Switch
N	Test CW Flow Switch
	Test CondW Flow Switch

### ANCILLARY PLANT Min/Maj

G	Clg Tower/ Dry Clr Condition
G	CHW Pump Set Condition
G	CondW Pump Set Condition
G	LTHW Pump Condition
F	Steam Trap Condition
Y	Primary Heat Source Vlv Oper.

### CONTROL SAFETIES Min/Maj

Standard	Micro	
14.6 BarG	9.7 BarG	Gen H.P Cut-Out
N/A	1.8 BarG	LTL Cut-Out
N/A	0.1 BarG	Chryst. Safety S.P
N/A	4.1 BarG	Ref. Pmp Safety
UNTESTED		Actual Gen H.P Cut-Out Press
7.0 Deg C		Temp Control S.P
1.0 Deg C		Temp Control S.P - C/O
55.0 Deg C		Gen Temp S.P
100 Mins		Max Valve Open Pos
-		Max CondW Temp
87.0 Deg C		Max Generator Temp
20 Mins		Max CondW Temp
87.0 Deg C		Max Generator Temp
22.0 Deg K		Max Loading S.P

### UNIT CONDITION Min/Maj

F	Check Panels & Paintwork		
F	Check Insulation		
G	Check Pipework		
G	Check Solenoid Valves		
G	G	G	Sight Glass LVLs

### OPERATION CHECKS Min/Maj

SITE	DESIGN	GENERATOR DATA
64.0 DegC	65.0 DegC	LTHW Temperature Inlet
55.0 DegC	55.0 DegC	LTHW Temperatur Outlet
5.0 DegC	5.0 DegC	LTHW Temp Differential (A)
-	-	LTHW Inlet Pressure
-	-	LTHW Outlet Pressure
#VALUE!	#VALUE!	LTHW Generator P.D Full Flow
8.0 L/S	10.0 L/S	LTHW Flow Rate (B)
		Generator Pressure
		Strong Solution Temp (GEN)
		Strong Solution Concentration
	100.0	LTHW Valve Position (% OPEN)
		Generator Approach

SITE	DESIGN	EVAPORATOR DATA
12.0 DegC	12.0 DegC	CHW Inlet Temperature
6.3 DegC	6.0 DegC	CHW Outlet Temperature
5.7 DegC	6.0 DegC	CHW Temperature Diff (E)
		CHW Inlet Pressure
		CHW Outlet Pressure
		CHW Pressure Differential
20.7 L/S	20.7 L/S	CHW Flow Rate (F)
		Refrigerant Cond. Temperature
		Refrigerant Pressure
		Refrigerant Sat Temperature

N IS FURTHER WORK NEEDED. (Identify Below)


### OPERATION CHECKS Min/Maj

SITE	DESIGN	ABSORBER DATA
28.8 DegC	31.0 DegC	CDW Inlet Temperature
33.8 DegC	36.0 DegC	CDW Outlet Temperature
		CDW Temperature Leaving Absorber.
5.0 DegC	5.0 DegC	CDW Temperature Differential (C)
-	-	CDW Inlet Pressure
-	-	CDW Outlet Temperature
-	-	CDW Pressure Differential
-	-	CDW Pressure Differential Full Bypass
31.1 L/S	31.1 L/S	CDW Flow Rate (D)
-	-	HX Outlet Temperature (ABSORB)
-	-	Weak Solution Temperature (TO HX)
-	-	HX Outlet Temperature (ABSORB)
-	-	Weak Solution Temperature (TO HX)

### SOLUTION MAKE UP

90.0 KG	Refrigerant (H2O)
620.0 KG	Lithium Bromide (LiBr 50WT%)
360.0 CC	Inhibitor (Li2MoO4)
1120.0 CC	Octyle Alcohol (CH3(CH2)5CH(OH)CH3)

### BALANCE DATA Maj



	GENERATOR	+	EVAPORATOR	=	ABSORBER
	(A * B * 4.187)	+	(E * F * 4.187)	=	(C * D * 4.127)
<b>DESIGN</b>	209.4 kW	+	519.8 kW	=	651.1 kW
<b>SITE COND</b>	167.5 kW	+	494.0 kW	=	651.1 kW

### FAULTS FOUND:

\*1 NO FAULTS FOUND

ENGINEER SIGNATURE: \_\_\_\_\_

CUSTOMERS SIGNATURE: \_\_\_\_\_

DATE: 00/01/1900

## PPM REPORT - CHILLER LOGS

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION			SHEET NUMBER <b>00000</b>
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO	F-GAS QUALIFICATION C&G 2079 PART 1		CLIENT ASSET NUMBER <b>00000</b>
REASON FOR VISIT A VISIT	MANUFACTURER A MANUFACTURER	MODEL	A MODEL NUMBER		
JOB NUMBER A JOB	SERIAL No. A SERIAL NUMBER	YEAR INSTALLED	01/01/1980		
PLANT LOCATION A LOCATION	REFRIGERANT TYPE R22	QUANTITY (KG)	240.0 KG		
PLANT REFERENCE A PLANT REFERENCE	CLG LOAD SERVED A COOLING LOAD SERVED				

### TURBOCOR COMPRESSOR LOG CAPTURE





## PPM REPORT - MULTISPLIT/VRV SYSTEM

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION				SHEET NUMBER <b>00000</b>			
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO	F-GAS QUALIFICATION C&G 2079 PART 1			CLIENT ASSET NUMBER <b>00000</b>			
REASON FOR VISIT A VISIT	MANUFACTURER A MANUFACTURER	MODEL A MODEL NUMBER	A MODEL NUMBER						
JOB NUMBER A JOB	SERIAL No. A SERIAL NUMBER	YEAR INSTALLED 01/01/1980							
PLANT LOCATION A LOCATION	REFRIGERANT TYPE R22	QUANTITY (KG) 240.0 KG							
PLANT REFERENCE A PLANT REFERENCE	CLG LOAD SERVED A COOLING LOAD SERVED								

### VRV CONDENSING UNIT SERVING 1ST FLOOR MEETING ROOMS

REFERENCE	CONDENSER MODEL	SERIAL	COMPRESSOR MODEL	CONDENSER MODE	FIXED COMP CURRENT	VAR. COMP CURRENT	CONDENSER FAN CURRENT	COMP SUCTION PRESSURE	COMP DISCH. PRESSURE	SUCTION TEMPERATURE	DISCHARGE TEMPERATURE	SYSTEM REFRIG. CHARGE	F-GAS REFRIG. LEAK TEST	ONE SHOT ACID / MOIST. RESULT
OUTDOOR UNIT	FDC400KXRE6	W402000513F	INV+FIXED	COOLING	0.0 A 3PH	12.3 A 3PH	1.4 A 1PH	6.90 BarG	26.30 BarG	-	-	<b>FULL</b>	<b>PASS</b>	-
				HEATING	0.0 A 3PH	11.9 A 3PH	2.2 A 1PH	8.40 BarG	32.40 BarG	N/A	N/A	<b>FULL</b>		

### 1ST FLOOR - MEETING ROOM 1-A (RIGHT) VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 1A	MITSI HEAVY	FDUM28KXE6D	928200053PK	0.1 A 1PH	22.5 C	11.5 C	29.8 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

### 1ST FLOOR - MEETING ROOM 1-B (REAR) VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 1B	MITSI HEAVY	FDUM28KXE6D	928200065PK	0.1 A 1PH	24.3 C	13.2 C	31.1 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

### 1ST FLOOR - MEETING ROOM 2 VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 2	MITSI HEAVY	FDUM28KXE6D	928200849PK	0.1 A 1PH	22.8 C	12.8 C	32.5 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

### 1ST FLOOR - MEETING ROOM 3 VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 3	MITSI HEAVY	FDUM28KXE6D	928200122PK	0.1 A 1PH	24.3 C	12.9 C	32.1 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

### 1ST FLOOR - MEETING ROOM 4 VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 4	MITSI HEAVY	FDUM28KXE6D	928200124PK	0.1 A 1PH	22.4 C	11.6 C	29.6 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

### 1ST FLOOR - MEETING ROOM 5 VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 5	MITSI HEAVY	FDUM28KXE6D	928200118PK	0.1 A 1PH	23.2 C	13.2 C	29.5 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

### 1ST FLOOR - MEETING ROOM 6 VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 6	MITSI HEAVY	FDUM28KXE6D	928200199PK	0.1 A 1PH	22.6 C	11.9 C	32.2 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

### 1ST FLOOR - MEETING ROOM 7 VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 7	MITSI HEAVY	FDUM28KXE6D	928200200PK	0.1 A 1PH	20.7 C	10.8 C	29.9 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

### 1ST FLOOR - MEETING ROOM 8 VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 8	MITSI HEAVY	FDUM45KXE6D	945200631PK	0.1 A 1PH	23.7 C	12.4 C	31.5 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

### 1ST FLOOR - MEETING ROOM 9A (FRONT) VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 9A	MITSI HEAVY	FDUM45KXE6D	945200626PK	0.1 A 1PH	21.8 C	10.5 C	32.4 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

### 1ST FLOOR - MEETING ROOM 9B (REAR) VRV INDOOR UNIT.

REFERENCE	MANUFACTURE	MODEL	SERIAL	EVAP FAN CURRENT	EVAP AIR ON TEMP (C)	EVAP AIR OFF TEMP - GLG (C)	EVAP AIR OFF TEMP - HTG (C)	SENSOR CALIBRATION	DRAIN	RETURN AIR FILTER	ELECTRIC HARNESS	CONTROLLER PROGRAMMING	FCU F-GAS LEAK TEST	BRANCH BOX F-GAS LEAK TEST
MEETING RM 9B	MITSI HEAVY	FDUM45KXE6D	945201892PK	0.1 A 1PH	22.1 C	11.5 C	32.6 C	TESTED OK	TESTED OK	WASHED	CHECKED OK	CENTRAL	<b>PASS</b>	<b>PASS</b>

**FAULTS FOUND:**  
\* NO FAULTS TO REPORT

ENGINEER SIGNATURE: \_\_\_\_\_ CUSTOMERS SIGNATURE: \_\_\_\_\_ DATE: 00/01/1900

## PPM REPORT - FCU & CONTROLS

CUSTOMER NAME ACL ENGINEERING LTD		SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION			SHEET NUMBER <b>00000</b>	
SITE NAME & ADDRESS CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE		ENGINEER STEVE ORLANDO				
		F-GAS QUALIFICATION CITY & GUILD 2079 PART I				
REASON FOR VISIT A VISIT		MANUFACTURER A MANUFACTURER	MODEL	A MODEL NUMBER		
JOB NUMBER A JOB		SERIAL No. A SERIAL NUMBER	YEAR INSTALLED	01/01/1980		
PLANT LOCATION A LOCATION		REFRIGERANT TYPE R22	QUANTITY (KG)	240.0 KG		
PLANT REFERENCE A PLANT REFERENCE		CLG LOAD SERVED A COOLING LOAD SERVED				

**BOX CODES**    Y YES    N NO    G GOOD    F FAIR    P POOR    B BAD    N/A NOT APPLICABLE

FCU REF:	FCU MAN	FCU MOD:	FCU SER:	CONTROLLER TYPE	SENSOR CAL & SOFTWARE	TEST FAN SPEEDS	HTG VLV & ACTUATORS	CLG VLV & ACTUATORS	SUPP HTG VLV & ACT (RADS)	FILTER STATUS	TEST DRAIN	FAULTS
	DUNHAM BUSH	F6HBL4	137166	TREND IQ212 & SONTAY	OK / BACKED UP	I / II / III ALL OK	N/A	GOOD / GOOD	GOOD / GOOD	VACUUMED	FAIL	Y
3.2	DUNHAM BUSH	F6HBL4	137166	TREND IQ212 & SONTAY	OK / BACKED UP	I / II / III ALL OK	N/A	GOOD / GOOD	GOOD / GOOD	VACUUMED	FAIL	Y

**FAULTS FOUND:**

\*1 NO FAULTS

ENGINEER SIGNATURE: \_\_\_\_\_

CUSTOMERS SIGNATURE: \_\_\_\_\_

DATE: 00/01/1900



## YORK ISN CONTROLS PPM

CUSTOMER NAME ACL ENGINEERING LTD	SITE CONTACT (OPERATOR RESPONSIBLE FOR F-GAS COMPLIANCE) A NAME - A POSITION	SHEET NUMBER <b>00000</b>
SITE NAME & ADDRESS (PLANT OWNER F-GAS) CRN LTD, BANK HOUSE, PRIMOTT RD, STEVENAGE. SG1 3EE	ENGINEER STEVE ORLANDO	
	QUALIFICATION C&G 2079 PART 1	

### HARDWARE CHECKS

ITEM	OUTSTATION 1	OUTSTATION 2	OUTSTATION 3	OUTSTATION 4	OUTSTATIONS 5, 6 & 7.
MANUFACTURER	YORK	YORK	YORK	YORK	YORK
MODEL	ISN EDC 4800	ISN LDC 17	ISN EDC 4800	ISN LDC 17	TDC YT
SERIAL					
SOFTWARE VERSION	EDC 4.1	LDC 4.1	EDC 4.4	LDC 6.6	T6.6Y
NODE NUMBER	01	02	06	99	03 & 04 & 05
LAN NUMBER	00	00	00	00	PORT 2 RS485
IDENTIFIER	THAMES HOUSE	BUSH TOWER	PRINCESS HOUSE	SEQUENCER	CHILLER LINCS
CHECK POWER SUPPLIES AND RECORD	OK	OK	OK	OK	OK, OK, OK
CHECK CONDITION OF FUSES AND REPLACE AS NECESSARY	OK	OK	OK	OK	OK, OK, OK
CHECK CONDITION OF HARNESSSES AND RIBBON CABLES	POOR	POOR	POOR	OK	OK, OK, OK
CHECK EPROMS AND MICRO-CHIPS ARE CORRECTLY SEATED	OK	BAD	OK	OK	OK, OK, OK
CHECK BATTERY VOLTAGE AND RECORD	3.5	3.5	3.5	3.5	CAPACITOR
CHECK WATCHDOG OPERATION	OK	FAIL	OK	OK	CAPACITOR
CHECK OPERATION OF KEYPAD, DISPLAY AND AUDABLE ALARM	OK	FAIL	OK	OK	OK, OK, OK

### SOFTWARE CHECKS

CHECK ALARM TABLES FOR ACTIVE ALARMS RECORD AND CLEAR.	OK	FAIL	OK	OK	OK, OK, OK
CHECH TIME AND DATE, CORRECT FOR DAYLIGHT SAVINGS.	OK	FAIL	OK	OK	OK, OK, OK
CHECK ADVISORY ERRORS AND RECORD AND CLEAR.	OK	FAIL	OK	OK	OK, OK, OK
CHECK OPERATION OF ANOLOGUE AND DIGITAL HISTORIES.	OK	FAIL	OK	OK	OK, OK, OK
CHECK PASSWORDS AND RECORD ALL LEVELS.	5555, 8989, 1, 2, 3.	5555, 1, 2.	5555, 1, 3.	5555, 4444, 3333, 2222, 1111	5555, 1, 7396.
BACK UP SOFTWARE	OK	FAIL	OK	OK	OK, OK, OK
CHECK OPERATION OF ALL COMMUNICATION CHANNELS.	OK	FAIL	OK	OK	OK, OK, OK

### FIELD INTERFACES

<b>ANOLOG INPUTS.</b> CHECK CALIBRATION OF SENSORS AND RECORD.	OK	FAIL	OK	OK	N/A
<b>STATUS / PULSE INPUTS.</b> CHECK OPERATION.	OK	FAIL	OK	OK	N/A
<b>SWITCHED OUTPUTS.</b> CHECK OPERATION.	OK	FAIL	OK	OK	N/A
<b>MONITORED OUTPUTS.</b> CHECK OPERATION.	N/A	FAIL	N/A	N/A	N/A
<b>MODULATING OUTPUTS.</b> CHECK OPERATION.	OK	FAIL	OK	OK	N/A

\* BUSH TOWER CONTROLLER CATASTROFIC FAILURE, REPLACEMENT MOTHER BOARD REQUIRED.